

AENOR

Certificate of conformity Plastics

001/007345

AENOR certifies that the organization

AQUATHERM GmbH

registered office BIGGEN, 5 D-57439 ATTENDORN (Alemania)

supplies Polypropylene random with modified cristallinity pipes (PP-RCT) and glass fiber (PP-RCT)/PP-RCT+GF /PP-RCT) for installation of hot and cold water inside the building structure

in compliance with Technical specification to RP 001.78

Description Trademark: AQUATHERM BLUE PIPE MF-RP OT
Fiberglass content: 6%
Fiberglass content of the middle layer: 15%

See annex for more information.

Production site BIGGEN, 5 D-57439 ATTENDORN (Alemania)

Certification scheme In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.78.

First issued on 2021-12-21

Validity date 2026-12-21



Rafael GARCÍA MEIRO
Chief Executive Officer

AENOR

Certificate of conformity Plastics

001/007345

Annex to Certificate

Description Trademark: AQUATHERM BLUE PIPE MF-RP OT
Fiberglass content: 6%
Fiberglass content of the middle layer: 15%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
4,0	32	1/8 ; 2/8 ; 4/8 ; 5/6	Yes
5,0	40 - 50 - 63 - 75 - 90 - 110 - 125 - 140 - 160 - 200 - 250 - 315 - 355 - 400 - 450	1/6 ; 2/6 ; 4/6 ; 5/4	Yes

First issued on 2021-12-21
Validity date 2026-12-21

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com

AENOR

Certificado de Conformidad Plásticos

001/007345

AENOR certifica que la organización

AQUATHERM GmbH

con domicilio social en BIGGEN, 5 D-57439 ATTENDORN (Alemania)

suministra Tubos de polipropileno random con estructura cristalina modificada (PP-RCT) y fibra de vidrio (PP-RCT)/PP-RCT + FV/PP-RCT) para instalaciones de agua caliente y fría en el interior de la estructura de los edificios

conformes con Especificación técnica al RP 001.78

Descripción Marca comercial: AQUATHERM BLUE PIPE MF-RP OT
Contenido en fibra de vidrio total: 6%
Contenido en fibra de vidrio de la capa intermedia: 15%

Más información en el anexo al certificado.

Centro(s) de producción BIGGEN, 5 D-57439 ATTENDORN (Alemania)

Esquema de certificación Para conceder este Certificado, AENOR ha ensayado el producto y ha comprobado el sistema de la calidad aplicado para su elaboración. AENOR realiza estas actividades periódicamente mientras el Certificado no haya sido anulado, según se establece en el Reglamento Particular RP 01.78.

Fecha de primera emisión 2021-12-21

Fecha de expiración 2026-12-21



Rafael GARCÍA MEIRO
Director General

Original Electrónico

AENOR

Certificado de Conformidad Plásticos

001/007345

Anexo al Certificado

Descripción Marca comercial: AQUATHERM BLUE PIPE MF-RP OT
Contenido en fibra de vidrio total: 6%
Contenido en fibra de vidrio de la capa intermedia: 15%

SERIE	DIÁMETROS (mm)	CLASE DE APLICACIÓN / PRESIÓN DE DISEÑO (bar)	OPACIDAD
4,0	32	1/8 ; 2/8 ; 4/8 ; 5/6	Si
5,0	40 - 50 - 63 - 75 - 90 - 110 - 125 - 140 - 160 - 200 - 250 - 315 - 355 - 400 - 450	1/6 ; 2/6 ; 4/6 ; 5/4	Si

Fecha de primera emisión 2021-12-21
Fecha de expiración 2026-12-21

Original Electrónico

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com